

FAX IN



MATT MYSZAK
18 Timothy Avenue
Castle Hill NSW 2154

Full Builder's Lic. 37887
Tel: (02) 9899 5757
Fax: (02) 9634 7103

March 28, 1999

Lane Cove Council
Environmental Health Services
48 Longueville Rd., Lane Cove

PR 80.30 / B461/95	
5450/99	
RECEIVED 29 MAR 1999	
DOCUMENT TYPE	<input type="checkbox"/>
FOLLOW UP ACTION	<input type="checkbox"/>
LOCATION CODE	D1405

Att: Gordon Dryburgh

Ref: Final Certificate for Addition to the dwelling at 6 Anglo Rd, Greenwich.

In respond to your note of outstanding matters to above mentioned job please find following:

1. Engineering certificates for concrete slab and steel beam are already submitted
2. Floor plan as built does not differentiate significantly from original plans.
(slight difference in size of sliding door)
3. Fence, deck, pergola was not included in building work contract.
4. Painting, rubbish removal are responsibility of the Owner.
5. Screen mesh is fitted to the gully.
6. Ceiling vent is workable as the roof space is to sufficient to ventilate (over 400 mm).

Yours Faithfully

Matt Myszak (Builder)

Star
Is this OK now
of 30-3-99.
OK 20/3/99

